## Appendix A – Glossary of Terms

Term	Description
ADMS	Advanced Distribution Management System
7.BWG	A software platform that enables the safe and efficient operation and
	optimization of the distribution grid, including functions such as automatic
	outage restoration.
APT	Area Planning Tool
	ComEd database of actual loads and 5-year projected future loads. APT
	receives actual load data for components monitored by SCADA through an
	automatic interface and calculates a weather-adjusted value. Utilized to
	view and analyze loads and component ratings to develop load forecasts
	and to identify overloaded components.
ATO	Automatic Throw Over
	Provide automatic selection of available utility or generator sources to
BE	maintain service continuity to connected loads.  Beneficial Electrification
DE	A term for replacing direct fossil fuel use with electricity in a manner that is
	operationally, economically, and/or socially beneficial depending on the
	context.
BES	Bulk Electric System
	All Transmission Elements operated at 100 kV or higher and Real Power
	and Reactive Power resources connected at 100 kV or higher. This does
	not include facilities used in the local distribution of electric energy.
CAIDI	Customer Average Interruption Duration Index
	The average outage duration that any given customer would experience
	(SAIDI/SAIFI) and can be viewed as the average restoration time measured
CAIFI	in minutes.
CAIFI	Customer Average Interruption Frequency Index The average number of interruptions for those customers who experience
	interruptions during the year. It is calculated by dividing the total annual
	number of customer interruptions by the total number of customers affected
	by interruptions. In determining the total number of customers affected,
	each customer is counted only once regardless of the number of customer
	interruptions that the customer may have experienced during the year.
CBD	Central Business District
CCVT	Capacitive Coupled Voltage Transformer
	A CCVT is a device used to convert high voltage into low voltage for
	metering, protection, and control of High Voltage systems.
CEATI	Centre for Energy Advancement through Technological Innovation
	Industry standards group.
CEGIS	ComEd Geographic Information System
CEMI	Customera Evperioneina Multiple Interruptions
	Customers Experiencing Multiple Interruptions  Measurement of customers experiencing multiple interruptions
	Measurement of customers experiencing multiple interruptions.  Consolidated Estimating Tool
	A New Business tool used to make various contracts between ComEd and
	a new customer. Utilized to learn new customer load and to obtain a copy
	of the Service Estimate Request.
	of the Colvido Edilliato Request.

Term	Description
CIMS	Customer Information and Management System
oc	ComEd's customer information and billing system.
DA ACI	Avoided Customer Interruptions due to Distribution Automation
Britio!	DA: A system comprising sensors, processors, information and
	communication networks, and switches, through which a utility can collect,
	automate, analyze, and optimize data to improve the operational efficiency
	of its distribution power system.
	ACI: Avoided customer interruptions
DER	Distributed Energy Resource
DLIX	DERs are devices deployed across the distribution grid, typically close to
	load and usually behind the meter, which can be used individually or in
	aggregate to provide value to the grid, individual customers, or
	both. Examples include rooftop photovoltaic solar panels, storage systems,
	a fleet of electric vehicles, energy efficiency, and demand management
Derecho	systems.  A line of intense, widespread, and fast-moving windstorms and sometimes
Defectio	·
	thunderstorms that moves across a great distance and is characterized by damaging winds.
DERMS	Distributed Energy Resource Management System
DERIVIS	
DCA	A software platform used to manage a group of DER assets.
DGA	Dissolved Gas Analysis
	An examination of electrical transformer oil contaminants. Insulating
	materials within electrical equipment liberate gases as they slowly break
	down over time. The composition and distribution of these dissolved gases
	are indicators of the effects of deterioration, and the rate of gas generation
DD	indicates the severity.
DR	Demand Response
	A change in the power consumption of an electric utility customer to better
TINA A	match the demand for power with the supply.
EIMA	Energy Infrastructure Modernization Act (EIMA)
EPRI	Electric Power Research Institute
	An independent, nonprofit organization that conducts research,
	development, and demonstration projects for the benefit of the public in the
E) (	United States and internationally.
EV	Electric Vehicle
E) (OE	A vehicle using an electric motor.
EVSE	EV Supply Equipment
	Equipment that delivers electrical energy from an electricity source to
	charge plug-in electric vehicle batteries.
FEJA	Future Energy Jobs Act (FEJA)
FLISR	Fault Location, Isolation, and Service Restoration
	An automated solution that locates and isolates permanent faults and
	restores power to healthy portions of affected distribution lines or feeders.
Functionalization	Refers to the separation of delivery assets and functions between
	distribution and transmission and is governed by the Federal Energy
	Regulatory Commission ("FERC") "Seven Factor Test." The Seven Factor
	Test refers to seven indicators identified in FERC's Order No. 888, which
	determine what is local distribution (as opposed to transmission) and thus
	subject to State jurisdiction for most purposes.

Term	Description
GIS	Geographic Information System
	A software platform that provides the ability to capture and analyze spatial
	and geographic data.
HVD	High Voltage Distribution
	All circuits operated at 69KV and circuits and sections of circuits operated
	at 138 kV and higher that meet the seven indicators of local distribution.
IEEE	Institute of Electrical and Electronics Engineers
	The world's largest technical professional organization dedicated to
	advancing technology for the benefit of humanity.
IT	Information Technology
' '	Equipment and systems that enable the control and monitoring of the
	distribution grid.
ITN	
IIIN	Investment Tracking Number
1.00	Number allocated to ComEd Capital or O&M projects.
LRP	Long Range Plan
	A rolling, 5-year, forward-looking plan that incorporates planned
	investments.
LTC	Load Tap Changer
	An apparatus for changing the connection to an electrical transformer from
	one tap to another to vary the turns ratio and hence control the output
	voltage under a varying load.
NATF	North American Transmission Forum
	A group of transmission owners and operators that formed after the 2003
	Northeast blackout. Tasked with helping system operators identify and
	correct problems in the areas of human performance, operating experience,
	physical and cyber security, and continuous improvement techniques.
NERC CIP	North American Electric Reliability Corporation Critical Infrastructure
	Protection
	NERC: A nonprofit corporation formed by the electric utility industry to
	promote the reliability and adequacy of bulk power transmission in the
	electric utility systems of North America.
	CIP: A national program to ensure the security of vulnerable and
	interconnected infrastructures of the United States.
NWA	Non-Wires Alternatives
	Electric utility system investments and operating practices that can defer or
	replace the need for specific transmission and/or distribution projects, at
	lower total resource costs, by reliably reducing transmission congestion or
	distribution system constraints at times of maximum demand in specific grid
	areas.
O&M	Operations and Maintenance
OMS	Outage Management System
Civio	A utility network management software application that models network
	topology for safe, efficient field operations related to outage restoration.
	These systems track, group, and display outages to manage service
	restoration activities safely and efficiently.
PMU	Phasor Measurement Units
	Device used on electric systems to improve operators' visibility. It measures
	a quantity called a phasor. A phasor tells the magnitude and phase angle
	for the AC voltage or current at a specific location on a power line. This
	Tiol the AC voltage of current at a specific location of a power line. This

Term	Description
	information can also be used to determine frequency and is useful for
	identifying and analyzing system conditions.
PV	Photovoltaic
	Equipment capable of producing electric current or voltage via
	electromagnetic radiation from visible light from the sun.
REACTS	Renewable Energy, Advanced Control, and Telemetry Systems
	ComEd program to design and build advancements to the utility
	communication and telemetry network.
Reliability	The measure of the continuity of electric service and the frequency and
	duration of service interruptions.
Resiliency	The ability to withstand and reduce the magnitude and/or duration of
	disruptive events, which includes the capability to anticipate, absorb, adapt
	to, and/or rapidly recover from such an event (e.g., major storms,
	heatwaves, etc.).
SAIDI	System Average Interruption Duration Index
	The average outage duration for each customer served. It is measured in
	minutes and is calculated by dividing the total duration of all customer
	interruptions by the total number of customers served.
SAIFI	System Average Interruption Frequency Index
	The average number of interruptions that a customer experienced. It is
	calculated by dividing the total number of customer interruptions by the total
	number of customers served.
SCADA	Supervisory Control and Data Acquisition
	A utility operational software application that enables the control and
	monitoring of system assets like breakers, reclosers, capacitor banks, etc.
T&D	Transmission and Distribution
URD cable	Underground Residential Development cable
	Specialty aluminum wire intended for use in residential construction and
	light to medium-duty commercial applications.
VO	Voltage Optimization
	Systematic, controlled reduction in the voltages received by an energy
	consumer to reduce energy use, power demand, and reactive power
\(\(\frac{1}{2}\)	demand.
XLPE	Crosslinked Polyethylene power cable